

Summary of Detected PFAS Compounds Raw Water Supply Sources 2/8/2023-2/20/2023

Sample Location	PFAS Compound <sup>(1)(2)</sup>													
	6:2 FTS	8:2 FTS	HFPO-DA	PFBS (Perfluorobutanesulfonic acid)	PFDA (Perfluorodecanoic acid)	PFHxA (Perfluorohexanoic acid)	PFBA	PFPeA	PFPeS	PFHpA (Perfluoroheptanoic acid)	PFHxS (Perfluorohexanesulfonic acid)	PFNA (Perfluorononanoic acid)	PFOS (Perfluorooctanesulfonic acid)	PFOA (Perfluorooctanoic acid)
BUD-2	0	0	U	0.94	0	0.41	0	0.76	0	0	0.63	0	0	0.48
BUD-4	0	0	U	6.5	0	3.3	2.4	4.7	0.47	0	3.5	0	10	4.3
BUD -7	0	0	U	8.8	0	5.2	2.9	7.3	0.48	0	4.5	0.5	9.6	5.1
CO-12A	0	0	U	0.67	0	0.3	0.62	0	0	0	0	0	0	0
CO-34	U	U	U	U	U	U	U	U	U	0.85	U	U	U	U
CB-5	U	U	U	U	U	U	U	U	U	1.2	U	U	U	U
CB-9	U	U	U	U	U	U	U	0.52	U	U	U	U	U	U
CB-13	U	U	U	U	0.8	U	U	U	U	U	U	U	U	U
CY-2	U	U	U	U	U	U	U	0.43	U	U	U	U	U	U
CY-6	U	U	U	U	U	U	U	0.46	U	U	U	U	U	0.33
CC-1	0	0	U	0	0	0.49	0	0.55	0	0	0.78	0	0	1.6
CC-5	U	U	U	U	U	U	U	0.38	0.51	U	U	U	U	U
CC-10	4.8	U	U	U	U	U	1.1	0.65	1.3	U	U	U	U	U
CC-12	U	U	U	U	U	U	0.72	U	U	U	U	U	U	0.47
ELW-10A	U	U	U	U	U	U	U	0.31	1.6	U	U	U	U	U
ELW-101	U	U	U	1.1	U	1.7	0.94	1.8	U	1	0.83	U	1	1.9
ELW-106	U	U	U	0.78	U	1.2	0.69	1.8	U	0.58	0.56	U	U	1.7
ELW-122	7.8	U	U	U	U	U	U	U	U	U	0.43	U	U	U
MB-155	U	U	U	1.7	U	2.4	2	3.9	U	1.1	1.4	U	3.5	2.7
MB-158	U	U	U	U	U	1.1	U	U	U	U	U	U	U	U
MB-160	U	0.66	U	U	U	U	U	1.1	U	U	U	U	U	U
MB-169	U	U	U	U	U	U	U	0.32	U	U	U	U	U	U
NWH-2	U	U	U	U	U	U	U	0.49	U	U	U	U	U	U
NWH-7	U	U	U	U	U	1.9	U	U	0.44	U	U	U	U	U
S-21-5	U	U	U	U	U	U	U	0.43	0.58	0.5	U	U	U	U
S-21-8	U	U	U	1.1	U	0.81	0.81	1.1	U	0.47	U	U	1.1	0.96
SCH-1	U	U	U	U	U	0.32	U	0.3	U	U	U	U	U	U
SCH-15	U	U	U	U	U	0.32	U	0.3	U	U	U	U	U	U
SP-41	U	U	U	U	U	0.35	U	0.5	U	U	U	U	U	0.29
SP-44	U	U	U	U	U	U	U	1	U	U	U	U	U	U
SP-46	U	U	U	U	U	U	U	0.45	U	U	U	U	U	U
ST-3	U	U	U	0.48	U	0.43	U	0.86	U	U	U	U	U	0.57
ST-10	U	U	U	U	U	1	U	0.43	U	U	U	U	U	U
RSWTPINFL	U	U	U	4.2	U	5.9	4.1	7.9	U	2.9	2.2	0.66	5.5	2.9
DESALRAW	U	U	U	3.1	U	2.6	2.6	3.7	0.37	1.3	1.7	U	3.1	U

Notes:

(1). Concentrations presented in nanograms per liter (ng/l) or parts per trillion (ppt).

(2). 0="U"=Compound not detected at concentration equal to or above respective method detection level (MDL).